



State of Vermont

WATER SUPPLY
AND
WASTEWATER DISPOSAL PERMIT

Case #:	WW-4-0877	<u>LAWS/REGULATIONS INVOLVED</u>
Applicant:	Town of Westford	Environmental Protection Rules
Address:	RR 1 Box 30	Effective September 10, 1982
	Westford, Vermont 05494	

This project, consisting of drilling a new well to serve the existing town hall/library and town office located off Route 128 in the town of Westford, Vermont is hereby approved under the requirements of the regulations named above, subject to the following conditions.

GENERAL

1. The project shall be completed as shown on the plans Sheet 1 of 1 "Proposed Subsurface Sewage Disposal Facility & Plumbing Details" (only for the proposed drilled well location) dated 7-17-73 last revised 7-7-95 prepared by Donald L. Hamlin Consulting Engineers, Inc. and which have been stamped "approved" by the Wastewater Management Division. The project shall not deviate from the approved plans without prior written approval from the Wastewater Management Division.
2. No alterations to the buildings other than those indicated on the approved plan or Water Supply and Wastewater Disposal Permit, which would change or affect the exterior water supply or wastewater disposal or the approved use of each building shall be allowed without prior review and approval from the Agency of Natural Resources.
3. The Wastewater Management Division now reviews the sewage and water systems for public buildings under 10 V.S.A., Chapter 61 - Water Supply and Wastewater Disposal Permit.

WATER SUPPLY

4. The well location shall meet all minimum separation distances required by the Environmental Protection Rules, Chapter 21, Water Supply Rule, Part 11-Small Scale Water Systems, Table A.
5. The project is approved for on-site water supply from a drilled well provided that the well is located as shown on the plans. No other means of obtaining potable water shall be allowed without prior review and approval by the Wastewater Management Division.
7. Prior to the construction of the water supply system, other than drilling of the well, complete engineering plans for such system shall be submitted to and approved by the Wastewater Management Division. The submission shall include yield test results, a copy of the driller's well completion report, sizing calculations, specifications for pumps, hydropneumatic tanks, and storage facilities (if needed), and copies of physical/chemical and bacteriological water quality analyses performed by a laboratory that is certified by the Vermont Department of Health.

Dated at Essex Junction, Vermont this 20TH day of July, 1995.

William C. Brierley, Commissioner
Department of Environmental Conservation

By 
Ernest P. Christianson
Regional Engineer

c For the Record
Westford Planning Commission
Westford Selectboard
Water Supply Division
Department of Labor and Industry
Donald L. Hamlin Consulting Engineers, Inc.